



BAZILIKA SAN ĠORĠ

Clarification Note 1 - Errata Corrigendum - SG001/2020

WORKS TENDER FOR THE DESIGN, SUPPLY, INSTALLATION AND COMMISSIONING OF AN ENERGY EFFICIENT LIGHTING SYSTEM FOR THE FAÇADE, BELFRIES, FLANKS AND DOME OF ST GEORGE'S BASILICA, VICTORIA, GOZO

Errata Corrigendum

The tender as issued indicated an erroneous luminous flux range for Type D luminaire (see section 4 – clause 4.2.4). Following are the revised correct technical specifications

4.2.4 Type D Luminaire – Projector Narrow Spot Light

Type D luminaire needs to satisfy the following requirements:

1. Light distribution type: LED Spot
2. Colour of light Warm White 3000K
3. Colour rendition index: CRI 95
4. Luminous flux range of luminaire: 5900lm to 6000lm
5. Failure rate: $0.1\% < 50000\text{h}$
6. Colour deviation: 1.5 SDCM
7. Minimum ingress protection: IP65